

CLIENT: Current, Inc 30 Tyler Street PO Box 120183 East Haven, CT 06512 Nate Elder

Test Report No: 176541-2

Date: May 7, 2003

SAMPLE ID:

The Client submitted and identified the following test material as Gray Material coated

.020" to .025" on 20 gauge galvanized steel.

DATE OF RECEIPT: Entered into SGS USTC sample tracking system on April 23, 2003 as STN 36335.

TESTING PERIOD:

May 6, 2003.

AUTHORIZATION:

Testing authorized by Nate Elder.

TEST REQUESTED: The submitted sample was tested for surface flammability in accordance with the

procedures outlined in ASTM E162-02e, "Surface Flammability of Materials Using a

Radiant Heat Energy Source".

TEST RESULTS:

Average Flame Spread Index

5.39

For detailed results see page 2.

Tested by

Signed for and on behalf of SGS U.S. Testing Company Inc.

Brian Ortega Test Technician Greg Banasky Supervisor Fire Technology

This report is issued by SGS U.S. Testing Company Inc. under its General Conditions for Testing Services (copy available on request). Testing's responsibility under this report is limited to proven negligence and will in no case be more than the amount of the testing fees. Except by special arrangement, samples are not retained by SGS U.S. Testing for more than 30 days. The results shown on this test report refer only to the sample(s) tested unless otherwise stated, under the conditions agreed upon. Anyone relying on this report should understand all of the details of the engagement. Neither the name, seals, marks nor insignia of SGS U.S. Testing may be used in any advertising or promotional materials without the prior written approval of SGS U.S. Testing. The test report cannot be reproduced, except in full, without prior written permission of SGS U.S. Testing Company Inc.

Report No.: 176541-1 Date: May 7, 2003

Page: 2

CLIENT: Current, Inc

PREPARATION AND CONDITIONING: Specimens were submitted in four pieces 6" wide by 18" long. Prior to testing the specimens were pre-dried for 24 hours at 140° F and then conditioned to equilibrium at a temperature of $73 \pm 5^{\circ}$ F and a relative humidity of $50 \pm 5\%$. The specimens were wrapped with aluminum foil.

TEST RESULTS:

Specimen Number	Flame Spread Factor, Fs	Heat Evolution Factor, Q	Flame Spread <u>Index, Is</u>
1	2.50	1.32	3.30
2	2.60	1.98	5.51
3	2.52	2.63	6.63
4	2 <u>.48</u>	2.63	<u>6.52</u>
Average	2.53	2.14	5.39

OBSERVATIONS: Surface flaming to the 9" mark was observed on all specimens. The Average Flame Spread Index is 5.39. The average temperature rise is 9° C.

End of Report